


State of Montana
Department of Environmental Quality
UNDERGROUND STORAGE TANK
INACTIVE/NON-OPERATING PERMIT

*Issued to: Earth Home Properties LLC, Owner
for EARTH HOME PROPERTIES LLC at Evening Star Dr, Emigrant
Facility Code #26123 Facility ID #34-10978*

DO NOT FILL

Inactive UST systems NOT approved to receive or dispense a regulated substance.

Tag #	Capacity	Substance Stored	Tank Status
4753	12,000	Diesel	Do Not Fill
4754	10,000	Diesel	Do Not Fill



Underground Storage Tank Section Supervisor

November 16, 2023

Date Issued

Next Inspection Due:
August 13, 2024

Expires:
November 11, 2024

Inactive/Non-Operating Permits issued to this facility after November 16, 2023 render this permit null and void.

This Inactive/Non-Operating Permit must be posted at the facility in a place where it can be easily viewed by inspectors, fuel distributors and employees.

An inactive UST system is required to be inspected every three (3) years for inactive requirements only.

State of Montana Department of Environmental Quality
DEQ Waste Management and Remediation Division, Underground Storage Tank Section
Compliance Inspection - Inactive COMPLIANCE PLAN

This Compliance Plan reflects the current state of your facility and supersedes any Corrective Action Plan you may have previously received.

November 16, 2023

UST System Violations at EARTH HOME PROPERTIES LLC, Emigrant
Facility Code #26123, System Facility ID #34-10978

Permit Renewal Date: **November 11, 2024** Next Compliance Inspection Due: **August 13, 2024**

Christian Budell inspected the following UST systems on 11/11/2021

DEQ Tag Number	Capacity in gallons	Product
4753	12000	Diesel
4754	10000	Diesel

RECOMMENDATIONS

The following recommendations are not violations. They reflect deficiencies in the installation or operation and maintenance of your facility. The department recommends that these deficiencies be corrected before they lead to violations of performance standards.

- * Your compliance inspection documents that a "Do Not Fill" operating permit is not visibly posted at your inactive facility or readily available during a required underground storage tank inspection. You are required to provide this documentation to the inspector before or during an inspection.

REMINDERS

The following tests must be conducted at your facility if they have not previously been completed. These reminders do not reflect violations at this time.

- * Inactive compliance inspections must be completed at least 90 days before the end of the three-year inspection cycle. Your next inactive compliance inspection must be completed before 8/13/2024.
- * Your compliance inspection documents that your last corrosion protection test was conducted on 11/11/2021. You are required to test your corrosion protection system every three years. Your next corrosion protection test must be conducted by 11/11/2024.